

Government of India
Kalawati Saran Children's Hospital

No.:KSCH/G.Store/2018-19/ 1885

Dated : 05/05/18

CORRIGENDUM

With reference to Tender Enquiry No.KSCH/G.Store/Medical Gases/2018-19/1714 dt.24th of April 2018 regarding Tender for Procurement of Medical Gases & Liquid Oxygen for Smt.SK Hospital & Kalawati Saran Children's Hospital, New Delhi. Based of representations received, following amendments have been approved by the committee.


Points Nos.	Points Advertised in the tender	Modified points
Page No.8 Point No.35 L	Certificate from Manufacturer for LMO of having available another storage unit in Delhi NCR in case of Manufacturing shutdown	Certificate from Manufacturer for LMO of having available storage unit in two different provinces in Northern India in case of any Manufacturing shutdown
Page No.8 Point No.35 M	Certificate from Manufacturer having one more manufacturing unit within Delhi/NCR	Certificate from Manufacturer having one more manufacturing unit in case of other gases (other than LMO) but except Liquid Nitrogen.
Page No.13 Point No.12	The firm has to make available back up of at least 150 bulk cylinders each for both the hospitals. A backup storage area of cylinders i.e.43x43 sq.mtrs. will be provided by the hospital.	The firm has to make available back up of at least 150 (75+75) bulk cylinders for both the hospitals. Appropriate area for backup storage for cylinders will be provided by the hospital.
Page No.13 Point No.14	The gases supplied will be sent for quality test to any of Govt. approved lab from time to time and the cost of testing and transportation or any other incidental charges will be borne by the supplier. Also firm should have in house facility of testing of cylinders & CCE approved test shop.	<u>Point No.14A</u> The gases supplied will be sent randomly for quality test to any of Govt. approved lab from time to time and the cost of testing and transportation or any other incidental charges will be borne by the Hospital. <u>Point No.14B</u> Firm must have in house facility of testing of cylinders & CCE approved test shop.
Page No.14 Point No.20(a)	Should be certified for medical use (for Cryo therapy) as per IP 2014 or latest.	Should be for Cryo therapy use.
Page No.14 Point No.21	Specification of Air/Nitrous Oxide/Nitrogen(liquid)	Specification of Air
Page No.15 Point No.22	Specification of Medical CO2 a. Medical Use b. Should not damage any instrument/equipment c. Certified safe for human use d. Should supplied in company owned cylinders	Specification of Medical CO2 a. Should not damage any instrument/equipment b. Safe for human use c. Should be supplied in company owned cylinders

Page No.15	New Addition	Note : A,AA and B type cylinders will be provided by the hospital, in case supplier is not able to supply. However filling, servicing and calibration will be done by the supplier only.
Page No.15	New Addition	Note : Supply of Medical Gases will be delivered to hospitals in day time only except under special conditions/circumstances with permission from Competent Authority of Hospital.
Page No.15	New Addition	Note : The backup cylinder storage area is within the New Gas Manifold of KSCH premises & same is with SSKH. Cylinders will be delivered directly by supplier at both sites separately. There is no internal transportation mechanism required.

Important Dates :

Last Date of Submission of Tender:
24.5.18 up to 11.00 AM

Date & Time of Opening of Tender :
24.5.18 at 11.30 AM in Seminar Hall


05/05/18
Dr.Sunita Khambra,
Additional Medical Superintendent